


- NOTES:
1. IF 18" OF COVER IS NOT POSSIBLE UNDER CROSSING, USE DUCTILE IRON PIPE LINED WITH PROTECTO 401 WITH MIN THICKNESS OF 40 MILS.
 2. TRANSITION FROM PVC TO DIP USING GASKETED PVC SLIP-ON TRANSITION COUPLINGS (NO FERNCO OR MJ COUPLINGS) WHERE REQUIRED.
 3. THIS DETAIL ALSO APPLIES TO UN-PIPED DITCH CROSSINGS OR SWALES WITH LESS THAN 36" OF COVER.

MOUNT PLEASANT WATERWORKS WASTEWATER LATERAL CROSSING WITH LESS THAN 18" OF COVER			
APPROVED BY:		DATE:	WW-04
MPW		OCT 2013	
SCALE:	NTS	REVISED:	OCT 2013