



NOTE: REFER TO HIGHWAY DEPARTMENT, CITY, OR COUNTY PERMITS FOR ADDITIONAL REQUIREMENTS

DEPTH SCHEDULE FOR HAUNCHING AND BEDDING				
PIPE DIA.	4"-10"	12"-18"	2'-0"	3'-0"
"A"	6"	8"	10"	12"
"B"	TO CENTERLINE OF PIPE		20"	27"

EMBEDMENT COMPACTION SHALL BE THE MINIMUM DENSITIES INDICATED IN TABLE 2 OF ASTM D2321-L.R.

MOUNT PLEASANT WATERWORKS

PIPING UNDER NON-SCDOT PAVEMENT OR DRIVEWAYS

APPROVED BY:

MPW

SCALE:

NTS



DATE:

OCT 2013

REVISED:

JULY 2017

DRAWING NO.

WW-09